

Protecting Our Water Environment



Metropolitan Water Reclamation District of Greater Chicago

***MONITORING AND RESEARCH
DEPARTMENT***

REPORT NO. 22-07

HANOVER PARK WATER RECLAMATION PLANT

FISCHER FARM MONITORING REPORT FOR

FIRST QUARTER 2022:

SPECIAL CONDITION 2

April 2022

Kari K. Steele
President

Barbara J. McGowan
Vice President

Marcelino Garcia
Chairman of Finance

Cameron Davis

Kimberly Du Buclet

Josina Morita

Chakena D. Perry

Eira L. Corral Sepúlveda

Mariyana T. Spyropoulos

Metropolitan Water Reclamation District of Greater Chicago

CECIL LUE-HING RESEARCH AND DEVELOPMENT COMPLEX
6001 WEST PERSHING ROAD CICERO, ILLINOIS 60804-4112

Edward W. Podczewinski, P.E.
Director of Monitoring and Research

April 25, 2022

Ms. Catherine Siders
Illinois Environmental Protection Agency
Bureau of Water
DWPC Compliance Section #19
1021 North Grand Avenue East
P.O. Box 19276
Springfield, Illinois 62794-9274

Dear Ms. Siders:

Subject: Hanover Park Water Reclamation Plant - Illinois Environmental Protection Agency
Permit No. 2022-SC-66896, Special Condition 2 Monitoring Report for January,
February, and March 2022

The attached table contains the monitoring data for the Hanover Park Water Reclamation Plant (WRP) Fischer Farm site for January, February, and March 2022, as required by Illinois Environmental Protection Agency (IEPA) Operating Permit No. 2022-SC-66896, Special Condition 2. Analytical data for well water samples collected during the quarter are presented in [Table 1](#).

Based on the investigation of historical high levels of ammonia nitrogen (NH₃-N) plus nitrite+nitrate nitrogen (NO₂+NO₃-N) in Well 7 during past monitoring, it appears that the source of these high levels is seepage from adjacent lagoons and subsurface drainage associated with supernatant application, both of which have high NH₃-N levels. Since implementing management practices to reduce the loading in adjacent lagoons and stop all applications of supernatant and biosolids in the closest farm field (Field 7), NH₃-N plus NO₂+NO₃-N in Well 7 has shown a decreasing trend, but with some significant fluctuation. We will continue to implement these practices and evaluate this trend.

The data reported are as follows:

[Table 1](#) Analysis of Water From Monitoring Wells W-5, W-6, W-7, and W-8 at the Hanover Park Fischer Farm Site Sampled in February 2022.

[Figure 1](#) Map of Fields and Wells at the Hanover Park Fischer Farm Site of the Metropolitan Water Reclamation District of Greater Chicago.

Very truly yours,



Albert E. Cox, Ph.D.
Environmental Monitoring and Research Manager
Monitoring and Research Department

AC:lf

Attachment

cc: Mr. J. Patel, Manager, IEPA – Des Plaines
Mr. T. Bennett, IEPA
Mr. B. Fleming, IEPA
Mr. K. Middleton, USEPA, Region 5
Mr. J. Chavich/Mr. B. Kaunelis
Mr. A. Gronski/Dr. H. Zhang

Metropolitan Water Reclamation District of Greater Chicago
100 East Erie Street Chicago, Illinois 60611-2803 (312) 751-5600

HANOVER PARK WATER RECLAMATION PLANT
FISCHER FARM MONITORING REPORT FOR FIRST QUARTER 2022:
SPECIAL CONDITION 2

TABLE 1: ANALYSIS OF WATER FROM MONITORING WELLS W-5, W-6, W-7, AND W-8 AT THE HANOVER PARK FISCHER FARM SITE SAMPLED IN FEBRUARY 2022¹

	Unit	W-5	W-6	W-7	W-8
pH ²		7.9	7.9	8.0	8.2
EC	mS m ⁻¹	68	70	62	55
Cl-	mg L ⁻¹	18	24	50	10
SO ₄ ²⁻	"	103	118	108	63
Alkalinity as CaCO ₃	"	310	295	107	276
TKN	"	<1.0	<1.0	1.7	<1.0
NH ₃ -N	"	0.33	0.37	<0.30	0.37
NO ₂ ⁻ +NO ₃ ⁻ -N	"	<0.25	<0.25	18	<0.25
Total P	"	<0.15	0.15	0.81	<0.15
Cd	"	<0.002	<0.002	<0.002	<0.002
Cr	"	<0.004	<0.004	<0.004	<0.004
Cu	"	0.010	0.053	0.017	0.011
Fe	"	3.7	22	9.9	5.3
Mn	"	0.032	0.17	0.084	0.039
Ni	"	<0.002	0.004	0.011	<0.002
Zn	"	<0.010	0.033	0.11	<0.010

¹Sampled on February 22, 2022.

²pH was measured beyond 15-minute holding time.

FIGURE 1: MAP OF FIELDS AND WELLS AT THE HANOVER PARK FISCHER FARM SITE OF THE METROPOLITAN WATER RECLAMATION DISTRICT OF GREATER CHICAGO

